


Truss to Corner Connection

Need to investigate

- 1) Wall to hanger Connection
- 2) hanger
- 3) hanger to truss Connection



Assume

- 1) $f'c = 2500$ psi with no reinforcement near the anchors
- 2) Truss chord material = 20ga min
- 3) Start using #10 SDS screws
- 4) use Hilti HY150 MAX post installed adhesive
- 5) use 3/8" threaded rod



~~###~~

1) Wall to hanger Connection

Find min loads:

$$T = (0.707)(1197) = 846\#$$

$$V = \sqrt{839^2 + 846^2} = 1192\#$$



allowable loads per Hilti Catalog

$$3/8" \phi @ h_e = 3 3/8 \quad T_{all} = 880\#/\text{Bolt} = 1760\#/\text{pair}$$

$$V_{all} = 1135 \quad = 2270$$

$$\frac{T}{T_{all}} = \frac{846}{1760} = 0.480$$

$$\frac{V}{V_{all}} = \frac{1192}{2270} = 0.525$$

1.005 > 1.0 No Good

Increase Rod Diameter to 1/2" ϕ

$$T_{all} = 1055\#/\text{Bolt} \Rightarrow 2110\#/\text{pair}$$

$$V_{all} = 1745 \Rightarrow 3490$$

$$\frac{T}{T_{all}} = \frac{846}{2110} = 0.401$$

$$\frac{V}{V_{all}} = \frac{1192}{3490} = 0.342$$

0.743 < 1.0 GOOD!



10/01/2013

Tuss to Corner Connection

2) hanger

$$T = 1197$$

$$V = 839$$

Use 16ga Grade 33 clip

$$T_{all} = 1986 \text{ \#/plate}$$

$$V_{all} = 3184 \text{ \#/plate}$$

$$\frac{T}{T_{all}} = \frac{1197}{(2)1986} = 0.301$$

$$\frac{V}{V_{all}} = \frac{839}{(2)3184} = 0.200$$

$$\left. \begin{array}{l} 0.301 \\ 0.200 \end{array} \right\} 0.501 < 1.0 \text{ GOOD!}$$

Pullout vs Pull over @ hanger to wall connection

$\frac{1}{2}$ " ϕ threaded rod $\Rightarrow 1\frac{1}{4}$ " outside diameter washer

Pull over Tension = 846 # applied over the first half of the washer edge

$$P_{aov} = \frac{1592}{2} = 796 \text{ \#/clip} = 1592 \text{ \#/connection} > 846 \text{ \#} \therefore \text{good!}$$

3) hanger to truss connection

use #10 SDS screws

$$P_{as} = 266 \text{ \#/screw}$$

$$R = \sqrt{839^2 + 1197^2} = 1462$$

$$\frac{1462}{255} \Rightarrow (6) \text{ \#10 SDS} \Rightarrow (3) \text{ per side}$$

$$(6)(255) = 1530 \text{ \#/connection}$$



10/01/2013

Find Max Capacity

1) $T_{max} = 2110 \#$
 $V_{max} = 3490$


2) $T_{max} = 1986$
 $V_{max} = 3184$

3) $T_{max} = 1530$
 $V_{max} = 1530$

Min Capacities

$V_{max} = 1530$

$T_{max} = 1530$



10/01/2013

truss to concrete wall connection at a corner

Threaded Rod capacity calculation

Applied tension	846 lbs
Applied Shear	1192 lbs
min embedment	3.375 in
edge distance:	4 in
Rod diameter:	0.50 in
F'c :	2500 psi

Anchor Capacities:			
Tension	3479	lbs	
Shear	1386	lbs	
CSI =	1.103	This will work.	

Tension

Nua =	1353.6
Vua =	1907.2
Nsa =	14190
ϕ =	0.65
n =	1
ϕ Nsa =	9224
ϕ Ncb =	3478.998
Anc =	91.75781
Anco =	102.5156
$\Psi_{ed,n}$ =	0.803704
$\Psi_{c,n}$ =	1
$\Psi_{cp,n}$ =	1
Nb =	7440.325
Kc =	24
ϕ =	0.65
Ca,min =	1.75
Na =	7570.126
Nao =	10523.35
$\tau_{k,cr}$ =	1985
Scr,na =	10.125
$\tau_{k,uncr}$ =	1985
Ccr,na =	5.0625
Anao =	102.5156
Ana =	91.75781
$\Psi_{ed,na}$ =	0.803704
$\Psi_{p,na}$ =	1
ϕ =	0.65
ϕ Na =	4920.582

Steel Capacity	9224
Concrete Capacity	3479
Adhesive Capacity	4921

Shear

Vsa	5815
ϕ =	0.6
ϕ Vsa =	3489
Vcb =	1979.899
Vb =	1979.899
ϕ =	0.7
Avc =	72
Avco =	72
$\Psi_{ed,v}$ =	1
$\Psi_{c,v}$ =	1
le =	4
ϕ Vcb =	1386
Kcp =	2
Na =	7570.126
Ncb =	5352.305
Vcp =	15140.25
ϕ =	0.7
ϕ Vcp =	10598

Steel Capacity	3489
Concrete Break out	1386
Concrete pryout	10598



10/16/2013

Truss to corner connection

Shear

2007 AISI

h 3 in
plate gauge 16ga
t 0.0566 in

Allowable Shear: 2101 lbs./plate

Applied Shear: 839 lbs/connection

$h/t = 53.00353$

$V/V_a = 0.3993$

$F_v = 19800$

$A_w = 0.1698$

$V_n = 3362.04 \text{ lbs}$

$\Omega = 1.6$

$V_a = 2101 \text{ lbs}$

$E = 29500000 \text{ psi}$


$K_v = 5.34$

$F_y = 33000 \text{ psi}$

0.1875

155.8933

$\sqrt{E K_v / F_y} = 69.09151$



10/01/2013

Truss to corner connection

Allowable Tension per 2007 NaSpec

Plate Gauge 16ga
thickness 0.0566
width 3
Fy 33000
Fu 45000
Hole Diameter 0.19
Number of holes 5
Hole Spacing 0.5625

Allowable Tension: 1986 lbs

Applied Tension: 1197 lbs./connec


T/Ta = 0.301

Ag = 0.1698 in²
Tn = 5603.4 lbs
Ta = 3355.329 lbs

An = 0.11603 in²
Tn = 5221.35 psi
Ta = 2610.675

An = 0.11603
Ft = 50100
Tn 5813.103
 Ω = 2.22
Ta 2618.515

Ft = 38000
Ta = 4409.14
 Ω = 2.22
Ta = 1986.099



10/01/2013

Screw Capacity, Based on 2007 North American Cold-formed steel Specification.

Gauge of plate next to screw head	16ga
Gauge of plate not next to screw head	20ga
Thickness of plate next to screw head	0.0566 (t1)
Thickness of plate not next to screw head	0.0346 (t2)
Ultimate tensile Strength for t1 (Fu)	45000 psi
Ultimate tensile Strength for t2 (Fu)	65000 psi

Fastener	#10		
Diameter of fastener	0.19	$\Omega =$	3
washer Diameter	0.3125		
		Pas =	255
t2/t1 =	0.611307	Paot =	121
		Paov =	398
Pns =	765.8674		
Pns =	1306.611	need	
Pns =	1153.737	T =	0
min =	765.8674	V =	1462
Pns =	1306.611	Min. No. of screws =	6
Pns =	1153.737		
min =	1153.737	T/Paov =	0
		V/Pas =	0.95447
pull out		csi =	0.95447
Pnot =	363		
$\Omega =$	3		
Paot =	121		
Pull Over			
Pnov =	1194		
$\Omega =$	3		
Paov =	398		



10/01/2013

Screw Capacity, Based on 2007 North American Cold-formed steel Specification.

Gauge of plate next to screw head	16ga
Gauge of plate not next to screw head	custom
Thickness of plate next to screw head	0.0566 (t1)
Thickness of plate not next to screw head	8 (t2)
Ultimate tensile Strength for t1 (Fu)	45000 psi
Ultimate tensile Strength for t2 (Fu)	80000 psi

Fastener	Custom
Diameter of fastener	0.5
washer Diameter	1.25

$$\Omega = 3$$

$$t2/t1 = 141.3428$$

$$Pas = 1146$$

$$Paot = \cancel{90667} \text{ N/A}$$

$$Paov = 1592$$

$$Pns = 5376000$$

$$Pns = 3438.45$$

$$Pns = 864000$$

$$\min = 3438.45$$

need

$$T = 423$$

$$V = 596$$

$$Pns = 3438.45$$

$$Pns = 864000$$

$$\min = 3438.45$$

$$T/Paov = 0.13286$$

$$V/Pas = 0.26$$

$$csi = 0.39286$$

~~pull out N/A~~

$$\cancel{Pnot = 272000}$$

$$\cancel{\Omega = 3}$$

$$\cancel{Paot = 90667}$$

Pull Over

$$Pnov = 4776$$

$$\Omega = 3$$

$$Paov = 1592$$



10/01/2013