





126°

126°

3.5" (89mm)
for top clip
8" (203mm)
for bottom clip

Clip A **1**0

3 / A.

* 12-c

6-1/2"

Pair Cut Section

Girder web placement: Center lines of supported trusses line up with center of girder web, as shown above. The girder web center is marked with a 🛨 as shown.

Bare metal thickness = 0.0538" (1.37mm) General Clip Information 16g ASTM A653 SS Grade 50 Class 1 G60

135°

Clip

w

135

3.5" (89mm)
for top clip
8" (203mm)
for bottom clip

General Notes:

- All edge distances are 3/8" (10mm) minimum.
 All end distances and spacing are 5/8" (16mm) minimum.
 Circled numbers represent the quantity of #12 5pt. self-drilling tapping screws.
 Girder must be analyzed with concentrated loads from supported trusses in line with center of correctly placed girder webs. "Clip Pair Cut Section" gives correct girder web placement information.
- Ģ Two clips must be used for one clip pair. Two clip pairs are required for connection as shown. Supported truss must be analyzed with clip type bearings.
- .₇ .6 = Clip Bend; Bend clip only once.
- $^{\circ}\text{R}_V$ refers to total vertical reaction of supported truss, $^{\circ}\text{R}_H$ refers to horizontal reaction of supported truss, and $^{\circ}\text{U}$ refers to uplift of supported truss. This connection is for two identical trusses with one truss on each face of the girder web. Calculations are per the 2004 addendum to the 2001 AISI North American Specification for
- cold—formed steel structures. 10.Fascia beam to be applied at bottom clip before screws are applied. Reference ASC job E0708008 detail D1 for fascia beam design and specifications. Additional screws will be required per this design.



www.TrusSteel.com

Missouri: 13389 Lakefront Drive / Earth City, MO 63045 / (800) 326-4102 **California:** 8351 Rovana Circle / Sacramento, CA 95828 / (800) 877-3678 Florida: 1950 Marley Drive / Haines City, FL 33844 / (800) 755-6001

> Cantilevered Corner Referencing Custom 45° Connection For Special Fascia Design 3-Ply Hipjack

ITW Building Components Group, Inc. shall not be responsible for any performance failure in a connection due to a deviation from this detail. Any variation from this detail shall be approved in advance by ITW Building Components Group, Inc.

Custom Detall: TS-CD-TT-4501-001

Custom Detail Category:

09/04/08

Truss-to-Truss Connection